



CERTIFICATE OF REGISTRATION

This is to certify that

Leader L.L.C.
P.O. Box 52706
Dubai
United Arab Emirates

Meets the requirements of the BM TRADA **Q-Mark International Fire Door Manufacture** scheme to **STD 096 - Issue 3 - 01/12/2015** which only operates in Bahrain, Egypt, Iraq, Jordan, Kuwait, Lebanon, Libya, Oman, Qatar, Saudi Arabia and The United Arab Emirates for the products on the attached schedule

A handwritten signature in black ink, appearing to read 'Karen Prendergast'.

Karen Prendergast
Divisional Director - Certification
BM TRADA

Certificate Number

076

Date of Initial Certification

14 July 2010

Date of last issue

17 April 2019

Date of Expiry

9 October 2019

Warringtonfire Testing and Certification Limited t/a BM TRADA, Chiltern House, Stocking Lane, High Wycombe, Buckinghamshire, HP14 4ND, UK
Registered Office: Warringtonfire Testing and Certification Limited, 10 Lower Grosvenor Place, London, SW1W 0EN, UK.
Reg No. 11371436.

This certificate remains the property of Warringtonfire Testing and Certification Limited. This certificate and all copies or reproductions of the certificate shall be returned to Warringtonfire Testing and Certification Limited or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BM TRADA or at the above address or at www.bmtrada.com

Registration Schedule

Establishment

Leader L.L.C.

Address

P.O. Box 52706, Dubai, United Arab Emirates

Scope

Assessment/ Test Report	Doorset Description	Rating	Test Type
Chilt/A01204	Leader – HO - 30	30min	BS476 Part 22
FEA/F01205	Leader – HO - 60	60min	BS476 Part 22
Chilt/A05151	Leader – HE - 90	90min	BS476 Part 22
FEA/F97097	Leader – HPP - 30	30min	BS476 Part 22
Chilt/A01015	Leader – HPP - 60	60min	BS476 Part 22
FEA/F97174	Leader – HP - 30	30min	BS476 Part 22
FEA/F96103	Leader – HP - 60	60min	BS476 Part 22
BMT/CNA/F15082	Leader – H – 120	120 min	BS476 Part 22
Chilt/A02066	Leader – S - 44	30min	BS476 Part 22
Chilt/A02067	Leader – S - 54	60min	BS476 Part 22
ChiltA/06218	Leader –WSCP – 60	60min	BS 476 Part 22
ChiltA/06218	Leader –WSCP – 90	90min	BS476 Part 22
ChiltA/06218	Leader –WSCP – 120	120min	BS476 Part 22
Chilt/RF10060	Leader – T1 – 30	30min	BS 476 Part 22
Chilt/RF11072	Leader – T1 – 60	60min	BS 476 Part 22
TBWIC/PF092-2	Leader –SLSAD – 30 (Doorset A)	30min	BS476 Part 22
TBWIC/PF092-2	Leader – SLSAD – 60 (Doorset B)	60min	BS476 Part 22
TBWIC/PF092-4	Leader –SADLD – 60	60min	BS476 Part 22
BMT/FEP/F15290	Leader- LSASD (Glazed)-90 Doorset A	90min	BS 476 Part 22
	Leader- LSASD -90 Doorset B	90min	BS 476 Part 22
WF 369677	Leader-LSADD- 90	90min	BS 476 Part 22
161207394	Leader –LSASD – 60 (Specimen 1)	60min	BS 476 Part 22
	Leader –LSASD – 60 (Specimen 2)	60min	BS 476 Part 22
161219402	Leader –LSASD – 90 (With Vision Panel) (Specimen 2)	90min	BS 476 Part 22
161219402	Leader –LSASD – 120 (With Vision Panel) (Specimen 1)	120min	BS 476 Part 22